



**MINISTRY OF HEALTH
STATE DEPARTMENT FOR MEDICAL SERVICES**

ADDENDUM NO.1

TO : ALL INTRESTED BIDDERS

DATE: 04TH MAY 2023

SUBJECT: EXTENSION OF TENDER SUBMISSION/CLOSING DATE TENDER NO: WP. ITEM D108/ NB/ NB/ 2202 JOB NO.10996B SUPPLY, INSTALLATION, TESTING AND COMMISSIONING OF 3NO. PASSENGER LIFTS AT AFYA HOUSE, MINISTRY OF HEALTH

During the Pre-bid Site meeting the following pertinent issues for clarifications were raised by one of the bidders;

S/NO	BIDDER INQUIRY	RESPONSE
1.	The tender document contradicts the capacity of lift to be supplied. On page 41 on technical specifications lift described is of 1000Kgs/ 13 pax while else on page 109 General specifications describes a 800Kgs/ 10 pax capacity. Which supersedes the other?	The lift to be supplied should be 800kg/10 pax as per the general and particular specs.
2.	Lift system in the technical specifications describes a Destination Control system type of lifts but the arrangement on site is not viable for the system. For there to be a VIP lift away from the general public use, it MUST operate in simplex operations. A destination control will therefore require more than three lifts in a closed system mode of operation which isn't the case. Kindly examine this and advice.	The 3No. lift systems to operate on simplex mode.
3.	Last concern is the timeline for the project. replacement of three (3) No working lifts takes more than 45 weeks due to the nature of decommissioning a single lift and re-installation, making good and hand over before moving to the next one. Kindly note.	Contract period to be maintained at 45 weeks (315days).

The above clarifications will form part of the Evaluation criteria.

In line with the above the above captioned tender is hereby extended to **Tuesday 09th May 2023 at 10.00 am** to allow bidders to take into account the above clarifications before submission of their bid documents.

Tom Ogora
For: PRINCIPAL SECRETARY